



Certificate of Compliance

Certificate: 1562877 (LR 98920)

Master Contract: 183729

Project: 1562877

Date Issued: 2004/07/09

Issued to: Young Chang Silicone Co., Ltd.

481-7 GaSan-Dong
KumChun-Gu
Seoul, 153-803
South Korea
Attention: Mr. H. W. Park

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C', 'US' and ▲



Issued by: David Briere, B.Eng.

Authorized by: C. George Tranquada, C.E.T.,
Manager, Audio/Video Team

PRODUCTS

CLASS 9052 30 - INSULATING DEVICES AND MATERIALS - Component - Transformer and Motor Insulation

CLASS 9052 80 - INSULATING DEVICES AND MATERIALS - Component - Transformer and Motor Insulation

Triple-insulated winding wire, type STW-B, rated 130C, 32-18AWG, 0.2-1.0mm for use as reinforced insulating system for isolating transformers.

Note: The materials are investigated for use only as part of an insulation system in transformers and motors

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.